

GENERAL MOTES

- USE TYPE "C" MANHOLE FOR DEPTHS OF LESS THAN 6' MEASURED FROM INVERT TO RIM.
- CONTRACTOR HAS OPTION TO CONSTRUCT TYPE "C" MANHOLE IN LIEU OF TYPE "E" MANHOLE FOR DEPTHS OF 6' OR MORE.
- 3. DESIGN APPLIES TO 4' TO 6' I.D. MANHOLES.
- MANHOLE GREATER THAN 18' IN DEPTH SHALL ONLY BE CONSTRUCTION PRECAST CONCRETE SECTIONS.
- USE NON-SHRINK GROUT FOR JOINTS, FILLETS AND PENETRATIONS.
- 6. COMPACT ALL BACKFILL AROUND MANHOLE TO 95%.
- POSITION MANHOLE OPENING OVER THE UPSTREAM SIDE OF MAIN LINE.

CONSTRUCTION NOTES

- A. CONCRETE PIPE SUPPORTS SHALL EXTEND OUTSIDE OF MANHOLE TO BELL OF FIRST JOINT AND SHALL CRADLE PIPE TO SPRING LINE NOT APPLICABLE FLEXIBLE PIPE.
- B. PIPE PENETRATION INTO MANHOLE SHALL BE FLUSH TO 2" MAX., MEASURED AT SPRINGLINE OF PIPE.
- C. MANHOLE MAY BE CONSTRUCTED OF CONGRETE BLOCK, GR. MS BRICK, POURED CONGRETE OR PRECAST REINFORCED CONGRETE IF BLOCK OR BRICK PLASTER INSIDE AND OUT WITH 1/2" MORTAR. SEE DWG. 2118 FOR DETAILS.
- D. PRECAST CONCRETE COVER, SEE DWG. 2107.
- B. USE MAX., 4 COURSES GR. MS BRICK ON UNPAVED STREET FOR FUTURE ADJUSTMENT OF MANHOLE FRAME TO PAVEMENT GRADE PLASTER INSIDE WITH 1/2" MORTAR.
- F. CONCRETE BASE TO BE POURED IN PLACE USING MO. 4
 BARS AT 6" O.C. RA. WAY FOR MANHOLE DEPTH OF 16'
 OR GREATER. NO. 4 BARS AT 12" O.C. EA. WAY FOR
 MANHOLE LESS THAN 16' IN DEPTH.
- H. INVERT ELEVATION OF STUB OR LATERAL AS SHOWN ON PLANS.
- J. 6" GROUT FILLET ON UPPER HALF OF PIPE AND AROUND BASE.
- K. USE A 5' X 5' CONCRETE PAD IN ALL AREAS.
- L. FRAME AND COVER, SEE DWG. 2110.
- M. CONCRETE, SEE SECTION 101.
- N. SLOPE 1" PER FT. FROM PIPE CROWN.
- . SHELF TO BE 9" WIDE MIN.
- Q. APPROVED WATERSTOP TO BE COMPATIBLE WITH TYPE OF PIPE.
- R. STEPS TO BE INSTALLED AS PER SPEC. SECTION 920.
- S. EMD (IN UNPAVED AREAS).
- T. IN UNPAVED AREAS SET FRAME TO GRADE AND SLOPE TOP OF PAD.

CITY OF ALBUQERQUE

REVISIONS
SEWER

MANHOLE TYPE "C"

DWG. 2101
Aug. 1986